



RAdata, Inc.
 27 Ironia Road, Unit 2
 Flanders, NJ 07836
 973-927-7303 Phone
 973-927-4980 Fax

Customer: [Redacted]
 Pleasant Avenue
 Upper Saddle River, NJ 074580000

Laboratory Results

Sample Number	Sample Location	Collected By	Collected From	Sample Date/Time
[Redacted]	Pleasant Avenue - Upper Saddle Ri	[Redacted]	Kitchen Tap	5/5/2018 2:00:00 PM
Parameter	Result	MCL #	Method	Analysis Date/Time
Arsenic	7.81 ug/l *	5 ug/l	Std Method 3113B	5/10/2018 12:03:00 PM

**Some or All of the parameters tested on this report
 DID NOT PASS NJ Drinking Water Standards.**

This report represents results associated to the point of collection location in the structure only. It is recommended that other locations within the structure where water can be consumed, be tested to verify compliance to state and federal drinking water regulations.

Raw Water

Reviewed and Approved by:

Timothy P. Kroder, Laboratory Manager

MCL - Maximum Contaminant Level

ND - Not Detected

* At the time of sampling this parameter does not meet NJDEP Standards for drinking water.

Note: Some/all of the results for the parameters listed above have been analyzed by a subcontract laboratory. Please review the attached results from the subcontracted laboratory

Friday, May 11, 2018

NJDEP Laboratory Certification # 14006

Page 1 of 1




Environmental and Laboratory Services
90 1/2 West Blackwell St., Dover, New Jersey 07801
(973) 989-0010 P, (973) 989-0156 F

Analytical Results

Date: May 11, 2018

Client:
Address:



Project: Pleasant Avenue

Sample description: Water / DWSC5248-1
Sample location: Kitchen Tap
Sampled by: Client
Sample date: 05/05/18
Sample Time: 14:00
Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Arsenic	SM3113B	7.81 µg/L	5 µg/L	05/10/18	12:03	1	1.00 µg/L

µg/L = micrograms per liter

All testing was done within the required holding time.

I certify that these samples were analyzed in accordance with procedures approved by the New Jersey Department of Environmental Protection.

Susan VanVeen (For SV)
Susan VanVeen, Lab Manager
NJ Laboratory Certification ID # 14013

May 11, 2018
Date