

Customer:

RAdata, Inc. 27 Ironia Road, Unit 2 Flanders, NJ 07836 973-927-7303 Phone 973-927-4980 Fax

Ware Road Upper Saddle River, NJ 074580000			Laboratory Results		
Sample Number	Sample Location	addle River Bo	Collected By Richard, Hand	Collected From Holding/Pressure Tanl	Sample Date/Time
Parameter	Result	MCL #	Meth	nod	Analysis Date/Time
Arsenic	10.8 ug/l *	5 ug/l	Std Method 3113B		5/10/2018 12:14:00 PM
Some or All of the parameters tested on this report DID NOT PASS NJ Drinking Water Standards. This report represents results associated to the point of collection location in the structure only. It is recommended that other locations within the structure where water can be consumed, be tested to verify compliance to state and federal drinking water regulations.					

Raw Water

Reviewed and Approved by:

Junt P. Kuder

Timothy P. Kroder, Laboratory Manager

MCL - Maximum Contaminant Level

ND - Not Detected

* At the time of sampling this parameter does not meet NJDEP Standards for drinking water.

Note: Some/all of the results for the parameters listed above have been analyzed by a subcontract laboratory. Please review the attached results from the subcontracted laboratory

Thursday, May 17, 2018

NJDEP Laboratory Certification # 14006