



RAdata, Inc.  
 27 Ironia Road, Unit 2  
 Flanders, NJ 07836  
 973-927-7303 Phone  
 973-927-4980 Fax

Customer: [Redacted]  
 [Redacted] Meadowbrook Road  
 Ramsey, NJ 074460000

## Laboratory Results

Sample Number	Sample Location	Collected By	Collected From	Sample Date/Time
[Redacted]	[Redacted] Meadowbrook Road - Upper Saddle	Richard, Hand	Bathroom Tap	5/5/2018 3:10:00 PM
Parameter	Result	MCL #	Method	Analysis Date/Time
Arsenic	6.96 ug/l *	5 ug/l	Std Method 3113B	5/10/2018 12:19:00 PM

**Some or All of the parameters tested on this report DID NOT PASS  
 NJ Drinking Water Standards.**

*This report represents results associated to the point of collection location in the structure only. It is recommended that other locations within the structure where water can be consumed, be tested to verify compliance to state and federal drinking water regulations.*

Raw Water

Reviewed and Approved by:

Timothy P. Kroder, Laboratory Manager

# MCL - Maximum Contaminant Level

ND - Not Detected

\* At the time of sampling this parameter does not meet NJDEP Standards for drinking water.

Note: Some/all of the results for the parameters listed above have been analyzed by a subcontract laboratory. Please review the attached results from the subcontracted laboratory